



NOTES:

1. WATER STOPS TO BE CONSTRUCTED UPSTREAM OF MANHOLES AND AT 500' MAX SPACING IN GROUNDWATER CONDITIONS AND WHERE TYPE 'C' BEDDING IS USED OR OTHER LOCATIONS IDENTIFIED BY THE ENGINEER.
2. WRAP PIPE WITH "RAM-NEK" OR EQUIVALENT WHERE PIPE IS EXPOSED TO CONCRETE PRIOR TO POURING.
3. EXCAVATION & BACKFILL SHALL BE AS SPECIFIED IN TRENCH DETAIL (WR-1.1 OR WR-2.1)(SSPWC 305).
4. USE TYPE B, CONCRETE SLURRY (SSPWC 337.08.01)

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			<h1>CUT-OFF COLLAR</h1>	WASHOE
				DRAWING NO: WR-1.2
				DATE: 7/09
				PAGE: 2