



NOTES:

1. SEWER LATERAL MATERIALS AND CONSTRUCTION SHALL CONFORM TO THE REQUIREMENTS OF SECTION 306 "STORM DRAIN, CULVERTS, AND SANITARY SEWER CONSTRUCTION" OF THE STANDARD SPECIFICATIONS
2. IN NO CASE SHALL A LATERAL CONNECT TO THE SEWER MAIN DIRECTLY ON TOP OF THE PIPE.
3. SEWER LATERALS SHALL HAVE A MINIMUM SLOPE OF 0.02 FT/FT
4. ALL JOINTS ON SEWER LATERALS SHALL BE COMPRESSION TYPE OR APPROVED SOLVENT WELD.
5. EXCAVATION & BACKFILL SHALL BE AS SPECIFIED FOR "TRENCH EXCAVATION & BACKFILL" IN SECTION 305.00 OF THE SSPWC.
6. THE LETTER 'S' SHALL BE STAMPED OR CHISELED IN THE TOP OF THE CURB, NOT LESS THAN 1-1/2" HIGH AND 3/16" DEEP, WHERE THE LATERAL CROSSES THE CURB.
7. ENCASE LATERAL CONNECTION IN CEMENT, STABILIZED SAND OR 2000 PSI CONCRETE FOLLOWING INSTALLATION. CONNECTION MUST BE INSPECTED BY THE COUNTY PRIOR TO BACKFILL.
8. LATERAL SHALL BE CUT BACK TO SOUND MATERIAL FOR COUPLING.
9. NO LATERAL CONNECTIONS SHALL BE MADE TO SANITARY SEWER 'INTERCEPTOR' LINES WITHOUT THE APPROVAL OF THE COUNTY.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			SEWER LATERAL	WASHOE
				DRAWING NO:
				WR-1.9
				DATE: 7/09
				PAGE: 9