



**LEGEND**

1. RIGID PVC MATERIAL.
2. ROUND STYLES.
3. SETTER ANCHORED IN PLACE FOR STABILITY.
4. LOCKING BY-PASS WITH STOP.
5. INDICATE ON PLANS WHETHER POSITIVE DISPLACEMENT OR COMPOUND SENSUS METER WITH REMOTE READ. DWR WILL APPROVE METER TYPE BASED ON SIZE AND APPLICATION. (ICE REGISTERS WITH FLEXNET END POINT TRANSMITTERS).
6. STYROFOAM INSULATION.
7. MIP INLET AND OUTLET CONNECTIONS TO MATCH SERVICE SIZE.
8. MUELLER ANGLE CHECK VALVE.
9. LOCKWING ANGLE VALVE.
10. CAST IRON FLAT TOP WITH LOCKING DEVICE AND 1 3/4" TRANSPONDER OPENINGS. EPOXY COAT RECLAIM METER TOPS PURPLE.
11. REMOTE READ WIRE.
12. INLINE CHECK VALVE.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			<b>1-1/2" &amp; 2" METER VAULTS</b>	WASHOE
				DRAWING NO: WR-2.11.3
				DATE: 7/09 PAGE: 23