



**NOTES:**

1. SENSUS COMPOUND METER SHALL HAVE REMOTE READING DEVICE. (ICE REGISTERS WITH FLEXNET END POINT TRANSMITTERS).
2. VAULT CONFIGURATION FOR 3 INCH COMPOUND SERIES METERS: MIN 4'-0" x 6'-6" CONCRETE VAULT W/ADJUSTABLE 36"x60" TORSION SPRING ASSISTED COVERS WITH H-20 WHEEL LOAD RATING AS REQUIRED FOR INCIDENTAL TRAFFIC. INCLUDE 1 3/4" TRANSPONDER OPENINGS IN LID.
3. PAINT EXPOSED DUCTILE IRON AND VALVES BLUE FOR WATER APPLICATIONS AND PURPLE FOR RECLAIMED APPLICATIONS.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:	WASHOE	
			<b>3" &amp; 4" METER VAULT</b>	DRAWING NO:	WR-2.11.4	
				DATE:	7/09	PAGE: 24