



NOTES:

1. PROVIDE LADDER WITH KNURLED (NON SKID) RUNGS. PROVIDE CLIPS BOLTED OR WELDED TO EDGE OF VAULT LID FOR LADDER SUPPORT. ALIGN MAIN LINE THROUGH VAULT SO THAT IT DOES NOT INTERFERE WITH LADDER.
2. MINIMUM 12" CLEARANCE BETWEEN DOUBLE CHECK ASSEMBLY AND PARALLEL WALL.
3. PAINT ALL EXPOSED DUCTILE IRON AND VALVES BLUE FOR WATER APPLICATIONS AND PURPLE FOR RECLAIMED WATER APPLICATIONS.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:	
			DOUBLE CHECK DETECTOR ASSEMBLY	WASHOE	
				DRAWING NO:	WR-2.16
				DATE: 7/09	PAGE: 29