



NOTES:

1. MINIMUM SPOUT OUTLET DIAMETER TO BE $\frac{3}{8}$ -INCH.
2. INSIDE SURFACE OF SPOUT TO BE SMOOTH, NO INTERNAL THREADS AT SPOUT EXIT.
3. SPOUT TO EXTEND BEYOND OUTSIDE DIAMETER OF PIPE.
4. SAMPLER TO BE ABLE TO THROTTLE BALL VALVE TO VARY SAMPLE FLOW RATE.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			SAMPLE PORT IN VAULT	WASHOE
				DRAWING NO: WR-2.19.1
				DATE: 7/09 PAGE: 32