



NOTES:

1. MOUNTING PLATFORM FOR SAMPLING STATION NOT SHOWN FOR CLARITY.
2. INSTALL PER MANUFACTURING SPECS.
3. SAMPLE PORT BOX SHALL BE INSTALLED BEHIND AND WITHIN 1' (ONE FOOT) FROM PROPERTY LINE AND INSIDE P.U.E. OR AS OTHERWISE DIRECTED BY ENGINEER.
4. SAMPLE PORT BOX SHALL NOT BE LOCATED IN THE SIDEWALK.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:	WASHOE	
			SAMPLE PORT IN METER BOX	DRAWING NO:	WR-2.19.2	
				DATE:	7/09	PAGE: 33