



NOTES:

1. PLATFORM NOT SHOWN FOR CLARITY.
2. INSTALL PER MANUFACTURER'S SPECS.
3. METER BOX SHALL BE INSTALLED BEHIND AND WITHIN 1' (ONE FOOT) FROM PROPERTY LINE AND INSIDE P.U.E. OR AS OTHERWISE DIRECTED BY ENGINEER.
4. METER BOX SHALL NOT BE LOCATED IN THE SIDEWALK.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			<b>SAMPLE PORT IN METER BOX WITH SERVICE</b>	WASHOE
				DRAWING NO: WR-2.19.3
				DATE: 5/09 PAGE: 34