



NOTES:

1. COMBINATION AIR RELEASE VALVES SHALL BE INSTALLED OUTSIDE OF PAVEMENT SECTION. SLOPE GROUND AWAY FROM VALVE BOX OR CONSTRUCT CURBING TO PROTECT FROM FLOODING BY SURFACE WATERS.
2. ALL PIPES SHALL HAVE POSITIVE SLOPE FROM MAIN LINE TO AIR/VACUUM VALVE. 30" MINIMUM TO TOP OF PIPE.
3. DESIGN ENGINEER SHALL DETERMINE THE SIZE OF THE COMBINATION AIR RELEASE ASSEMBLY.
4. EXCAVATION & BACKFILL SHALL BE AS SPECIFIED FOR "TRENCH EXCAVATION & BACKFILL" IN SECTION 305.00 OF THE SSPWC.
5. LOCATOR WIRE IS TO BE 12 GAUGE COATED COPPER WIRE OR APPROVED EQUAL.
6. EITHER USE 4" DIAMETER STEEL PIPE, FILLED WITH CONCRETE, AND PLACED IN 24" OF CONCRETE, OR USE 4"x4" REDWOOD POST, 4'-6" LONG, ATTACHING VENT PIPE WITH U-BOLTS IN TWO PLACES.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
1	ARJ	7/11	1" COMBINATION AIR RELEASE ASSEMBLY	WASHOE
2	ARJ	3/13		DRAWING NO: WR-2.4
2	ARJ	1/14		DATE: 7/09 PAGE: 14