



NOTES:

1. REQUIRES PRESSURE PLATE FABRICATED FROM 8" X 2-1/4" CHANNEL IRON.
2. IF MAIN IS AT EXTRA DEPTH, REQUEST ADDITIONAL 4" NIPPLES.
3. ALL EXPOSED METAL MUST BE COATED WITH MASTIC.
4. AMOUNT OF CONCRETE TO BE Poured FOR ANCHOR BLOCKS WILL BE DETERMINED BY SIZE OF PIPE AND SOIL CONDITIONS WITH A MINIMUM OF 1/2 CU. YD. OF CONCRETE ON EACH ANCHOR BLOCK. SUFFICIENT CONCRETE MUST BE Poured TO RESIST THRUST DUE TO PRESSURE IN THE PIPE. APPLICABLE THROUGH 10" ONLY. ANCHOR BLOCKS FOR LARGER SIZES TO BE SPECIFIED BY THE ENGINEER.
5. ANCHOR BLOCKS MUST BE KEYPED-IN AT LEAST 6" BELOW BOTTOM OF TRENCH AND KEYPED INTO UNDISTURBED SOIL.
6. GALVANIZED NIPPLE SHALL BE CONTINUOUS OR TACK WELDED AT EACH JOINT.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:	
			4" FLUSH VALVE ASSEMBLY TERMINUS	WASHOE	
				DRAWING NO:	WR-2.7
				DATE:	7/09
				PAGE:	17