



NOTES:

1. A TEST STATION SHALL BE LOCATED ADJACENT TO EACH FIRE HYDRANT, WHERE SHOWN ON THE PLANS, AND AT OTHER LOCATIONS SHOWN OR AS DIRECTED. MAXIMUM SPACING BETWEEN TEST STATIONS IS 500 FEET. EXTEND TRACER WIRE TO THE TEST STATION COVER. TRACER WIRE SHALL EXTEND A MINIMUM 12" BEYOND COVER.
2. TRACER WIRE SHALL BE PLACED UNDER SERVICE CONNECTIONS AND EXTEND UP TO METER BOX COVER.
3. TRACER WIRES SHALL BE CONNECTED TOGETHER USING AN APPROPRIATELY SIZED WIRE NUT. WRAP CONNECTION WITH U.L. LISTED ELECTRICAL TAPE.
4. PRIOR TO ACCEPTANCE OF THE WATER LINE, THE CONTRACTOR SHALL PERFORM A CONTINUITY TEST ON THE INSTALLED WIRE SYSTEM.
5. TRACER WIRE SHALL BE PLACED ON BEDDING MATERIAL PRIOR TO PIPE PLACEMENT.

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
			TEST STATION	WASHOE
				DRAWING NO:
				WR-2.9
				DATE: 7/09
				PAGE: 19