



NOTES

1. REMOVE EXIST ASPH SURFACE TO $\text{\textcircled{C}}$ STREET OR CROWN IN ROADWAY. RECONSTRUCT ROADWAY W/4" MIN TYPE 3 ASPH PLANTMIX ON 6" TYPE 2 CLASS B AGG BASE OR MATCH EXIST STRUCTURAL SEC. IF GREATER.
2. GRINDING OF EXIST ASPH SURFACE MAY BE PERMITTED BY CO. ENGINEER IF EXIST ASPH IS MIN 4" THICK & HAS A PAVEMENT CONDITION INDEX OF 65 OR GREATER.
3. MIN PROFILE ON CURB & GUTTER SHALL BE 0.5%.
4. ALL CONST SHALL BE IN ACCORDANCE W/LATEST EDITION OF THE STD SPECIFICATIONS FOR PUBLIC WORKS & THE LATEST WASHOE COUNTY DETAILS.
5. ALL BACKFILL BEHIND CURB SHALL MEET THE LATEST WASHOE COUNTY REQUIREMENTS.
6. FOR SIDEWALK REFER TO DWG. W-16.2

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:
1	Save old W-4 ¹ as new W-6	10/01vp	RETROFIT CURB & GUTTER	WASHOE
2	Re-do as W-6	2/04vp		DRAWING NO: W-1.6
				DATE: 7/99vp PAGE: 6