



TYP. SEC.
N.T.S.

NOTES

1. FOR ALL UTILITIES IN A COMMON TRENCH, SEE STANDARD DETAIL DWG. 1-3.
2. MAINTAIN A MIN SEPARATION OF 5' BETWEEN GAS LINE & WASHOE CO. UTILITIES WATER LINE.
3. 5' MIN FROM FINISHED GRADE TO FLOWLINE OF SANITARY SEWER.
4. MIN 7.5' PUBLIC UTILITY/TRAFFIC CONTROL SIGNAGE/PLOWED SNOW EASEMENT

NO.	REVISED	DATE	STANDARD DETAILS FOR PUBLIC WORKS CONSTRUCTION	SECTION:	WASHOE	
1	REDRAWAL	6/94 vp	UTILITY MAIN LOCATIONS	DRAWING NO:	W-2.1	
				DATE: 6/94 vp	PAGE:	8